

PLANNING AND DEVELOPMENT SERVICES **BUSINESS CENTER**

1001 Sarasota Center Blvd., Sarasota, FL 34240 4000 S. Tamiami Trail, Room 122, Venice, FL 34293 Sarasota (941) 861-6678 Venice (941) 861-3029

Coastal Construction Control Line (CCCL) Certificate

This form is required for New Construction and Substantial Improvements to structures seaward of the Coastal Construction Control Line (CCCL)*

Name: JA	UL HCRU	A KESTDE	<u> Permit N</u>):	JII RT	
Street Addres	ss: 3101	CASEY	KEY R		W BOHE-	
City: No	Komis	State	FL	Zip Code	34275	
	SECTIO	N I – Flood In	surance Rate N	lap (FIRM) In	formation	
Community Number	Panel Number	Suffix	FIRM Index date	Flood Zone/s	Base Flood Elevation	FDEP Elevation ⁺
40 1111	0021			1	160	

1	ber	date		Elevation	Elevation ⁺
125144 02	36 F	11-04-16	AE	10	18.4

SECTION II - Proposed Elevation Information

1.	Bottom of Lowest Horizontal Structural Member	22.0	ft.	
2.	Elevation Requirement	18.4	_ft.	
3.	Elevation of Highest Adjacent Grade	11.3	ft.	
4.	Elevation of Lowest Adjacent Grade	11.0	ft.	
5.	Elevation of Bottom of Pilings or Foundation	2.4	_ft.	
6.	Elevation of Top of Pile Cap or Grade Beam	3.8	_ft.	

SECTION III – Certification Statement (Registered engineer or architect to sign and seal SECTION V)

I certify that based upon development and/or review of structural design specifications, and plans for construction including consideration of the hydrostatic, hydrodynamic, and impact loading involved, that the designs and methods of construction are in accordance with accepted standards of practice for meeting the following provisions:

The bottom of the lowest horizontal structural member supporting the Lowest Floor (excluding the pilings or columns) is elevated to or above Base Flood Elevation or FDEP elevation requirement whichever is higher.

MAY 17 200



^{*} Sarasota County Code Article XVI. Floodprone Areas and Latest Edition of the Florida Building Code

^{*} For new construction and substantial improvements that extend wholly or partially seaward of CCCL.

The pile or column foundation, pile cap and/or grade beam, and structure attached thereto is anchored to resist flotation, collapse and lateral movement due to the effects of wind and water loads associated with the design flood elevations acting simultaneously on all of the structural components.

SECTION IV – Breakaway Construction Certification Statement (Registered engineer or architect to sign and seal SECTION V)

I certify that based upon the development and/or review of structural design, specifications and plans for subject construction that the design and methods of construction of the breakaway walls are in accordance with accepted standards of practice for meeting the following provisions:

Breakaway Wall collapse shall result from a water load less than that which would occur during the Base Flood; and

Access to such enclosure shall be the minimum necessary to allow for parking of vehicles (garage door) or limited storage of items used in connection with the premises (standard exterior door) or access to the habitable space above (stairway or elevator).

"Breakaway Wall" means a partition independent of supporting structural members that will withstand design wind forces, but will fail under hydrostatic, wave and run-up forces associated with the design storm surge. Under such conditions, the wall will fail in a manner such that it dissolves or breaks up into components that will not act as potentially damaging missiles.

S	SECTION V- Certification	
Certifier's Name:		ARCHITECT
License Number: A.R. 9		: VENICE DESIGN BROUP
Street Address: 138 East	VENICE AVE, SUIT	re D
City: VENICE	State: FL	Zip Code: 34283
Telephone Number: 941	- 786-1157 Fax:	941-486-4101
Signature:	Seal	



Florida Department of **Environmental Protection**

Bob Martinez Center 2600 Blair Stone Road Tallahassee, Florida 32399-2400 Rick Scott Governor

Carlos Lopez-Cantera Lt. Governor

Jonathan P. Steverson Secretary

May 3, 2017

CRD Enterprises c/o Kristina V. Tignor The Tignor Group P.A 1255 S. Tamiami Trail Sarasota, Florida 34239

Dear Ms. Kristina Tignor

Scour Elevation Site Specific Determination

Permit Number:

ST-1922

Property Owner Name: CRD Enterprises

Location of Subject Property: Between approximately 212 feet and 310 feet south of the Department of

Environmental Protection's reference monument R-94, in Sarasota County.

Project address:

3101 Casey Key Road, Nokomis, Sarasota.

This is in response to your letter received by the Department on April 27, 2017 requesting a site specific determination of the scour elevation requirement at the project address.

Pursuant to Subsection 3109, Florida Building Code, all habitable structures shall be elevated at or above an elevation which places the lowest horizontal member above the 100-year storm elevation as determined by the Florida Department of Environmental Protection in the report titled "One-Hundred year storm Elevation requirements for Habitable Structures Located Seaward of a Coastal Construction Control Line." Alternatively, an applicant may request that the Department of Environmental Protection determine a site-specific scour elevation for the applicant's proposed habitable structure as part of the environmental permit application process. Based on the survey and site plan submitted with your request, a site specific design grade (scour elevation) is + 3.0 feet (NAVD), or lower.

This determination does not relieve you from your responsibility to comply with the permitting requirements of any other local, state, or federal regulatory agency which has jurisdiction over the proposed activity. If you have any questions, concerns, or need additional information, please contact me at the letterhead address (add Mail Station 300), or by telephone at 850/245-7674.

Sincerely,

S. Muthuswamy, Permit Manager

Coastal Construction Control Line Program

Division of Water Resource Management

cc:

Kelly Cramer, Field Inspector

Kristina V. Tignor: ktignor@thetignorgroup.com