



1921

# PLANNING AND DEVELOPMENT SERVICES BUSINESS CENTER

1001 Sarasota Center Blvd., Sarasota, FL 34240  
4000 S. Tamiami Trail, Room 122, Venice, FL 34293  
Sarasota (941) 861-6678 Venice (941) 861-3029

## Coastal Construction Control Line (CCCL) Certificate

**This form is required for New Construction and Substantial Improvements to structures seaward of the Coastal Construction Control Line (CCCL)\***

Name: FRASER RESIDENCE - ADDITION Permit No: 17 114693 00 B1

Street Address: 1624 CASEY KEY RD

City: NOKOMIS State FL Zip Code 34275

### SECTION I – Flood Insurance Rate Map (FIRM) Information

Community Number	Panel Number	Suffix	FIRM Index date	Flood Zone/s	Base Flood Elevation	FDEP Elevation <sup>+</sup>
Insurance Map Number 12115C0238F			November 4/2016	AE	10'	18.3 NAVD

### SECTION II – Proposed Elevation Information

- |                                                  |                        |
|--------------------------------------------------|------------------------|
| 1. Bottom of Lowest Horizontal Structural Member | <u>18.3' NAVD</u> ft.  |
| 2. Elevation Requirement                         | <u>18.3' NAVD</u> ft.  |
| 3. Elevation of Highest Adjacent Grade           | <u>11.0' NAVD</u> ft.  |
| 4. Elevation of Lowest Adjacent Grade            | <u>3.4' NAVD</u> ft.   |
| 5. Elevation of Bottom of Pilings or Foundation  | <u>-30.0' NAVD</u> ft. |
| 6. Elevation of Top of Pile Cap or Grade Beam    | <u>7.2' NAVD</u> ft.   |

### SECTION III – Certification Statement

(Registered engineer or architect to sign and seal SECTION V)


I certify that based upon development and/or review of structural design specifications, and plans for construction including consideration of the hydrostatic, hydrodynamic, and impact loading involved, that the designs and methods of construction are in accordance with accepted standards of practice for meeting the following provisions:

The bottom of the lowest horizontal structural member supporting the Lowest Floor (excluding the pilings or columns) is elevated to or above Base Flood Elevation or FDEP elevation requirement whichever is higher.

GEORGE MERLIN

\* Sarasota County Code Article XVI, Flood-prone Areas, and Latest Edition of the Florida Building Code

+ For new construction and substantial improvements that extend wholly or partially seaward of CCCL.



The pile or column foundation, pile cap and/or grade beam, and structure attached thereto is anchored to resist flotation, collapse and lateral movement due to the effects of wind and water loads associated with the design flood elevations acting simultaneously on all of the structural components.

---

**SECTION IV – Breakaway Construction Certification Statement  
(Registered engineer or architect to sign and seal SECTION V)**

I certify that based upon the development and/or review of structural design, specifications and plans for subject construction that the design and methods of construction of the breakaway walls are in accordance with accepted standards of practice for meeting the following provisions:

Breakaway Wall collapse shall result from a water load less than that which would occur during the Base Flood; and

Access to such enclosure shall be the minimum necessary to allow for parking of vehicles (garage door) or limited storage of items used in connection with the premises (standard exterior door) or access to the habitable space above (stairway or elevator).

“Breakaway Wall” means a partition independent of supporting structural members that will withstand design wind forces, but will fail under hydrostatic, wave and run-up forces associated with the design storm surge. Under such conditions, the wall will fail in a manner such that it dissolves or breaks up into components that will not act as potentially damaging missiles.

---

**SECTION V- Certification**

Certifier's Name: GEORGE MERLIN Title: ARCHITECT  
License Number: AR0010623 Company Name: GEORGE MERLIN ASSOCIATES, INC  
Street Address: 7729 HOLIDAY DRIVE  
City: SARASOTA State: FLORIDA Zip Code: 34231  
Telephone Number: 941 923 8868 Fax: 941 9239148

Signature: GEORGE MERLIN

Seal:

