



OUR SCOPE



existing Buried LP Tank
w/ First Stage Regulator @10PSI



existing 100' of $\frac{3}{4}$ " PE

Longest Run: 100'


Total BTU: 330000

Table 16.1(n) NFPA 58 is attached

$\frac{3}{4}$ " PE Used for Installation



HANNY ORTIZ
Notary Public
State of Florida
Comm# HH517406
Expires 4/17/2028

Sheet Name Gas Riser Diagram	Designed Per: NEC 2020 FBC 2023 FGC 2023 8th Ed. NFPA 58		Qualifier Scott Campbell	Qualifier Signature 
Designed For Project Address 11870 Creek Shed Place, Sarasota, FL 34240			Master Electrical License EC13005984	
Customer Name/Title Wolff, Ted	Date	Revisions	Master Gas License LQ36055	RELIABLE POWER SYSTEMS
			Company Gas License LI28455	
				3400 SW 10th St, Deerfield Beach, FL, 33442