

**ELEVATION CERTIFICATE**

OMB No. 1660-0008  
Expires March 31, 2012

Important: Read the instructions on pages 1-9.

08-808560

Main House

**SECTION A - PROPERTY INFORMATION**

A1. Building Owner's Name George & Mary Hicks  
 A2. Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No. 840 N Casey Key Road  
 City Nokomis State Florida ZIP Code 34275  
 A3. Property Description (Lot and Block Numbers, Tax Parcel Number, Legal Description, etc.) Meters and Bounds, Section 9, Township 38 South, Range 18 East  
 A4. Building Use (e.g., Residential, Non-Residential, Addition, Accessory, etc.) Residential  
 A5. Latitude/Longitude: Lat 27° 11' 31" N Long 82° 30' 11" W Horizontal Datum:  NAD 1927  NAD 1983  
 A6. Attach at least 2 photographs of the building if the Certificate is being used to obtain flood insurance.  
 A7. Building Diagram Number 6  
 A8. For a building with a crawspace or enclosure(s):  
 a) Square footage of crawspace or enclosure(s) 2330 sq ft  
 b) No. of permanent flood openings in the crawspace or enclosure(s) within 1.0 foot above adjacent grade -0-  
 c) Total net area of flood openings in A8.b -0- sq in  
 d) Engineered flood openings?  Yes  No -0-  
 A9. For a building with an attached garage:  
 a) Square footage of attached garage N/A sq ft  
 b) No. of permanent flood openings in the attached garage within 1.0 foot above adjacent grade N/A  
 c) Total net area of flood openings in A9.b N/A sq in  
 d) Engineered flood openings?  Yes  No N/A

**SECTION B - FLOOD INSURANCE RATE MAP (FIRM) INFORMATION**

B1. NFIP Community Name & Community Number Sarasota County 125144 B2. County Name Sarasota B3. State Florida  
 B4. Map/Panel Number 125144-0228 B5. Suffix E B6. FIRM Index Date 9-3-1992 B7. FIRM Panel Effective/Revised Date 9-3-1992 B8. Flood Zone(s) AE B9. Base Flood Elevation(s) (Zone AO, use base flood depth) 11 ft.  
 B10. Indicate the source of the Base Flood Elevation (BFE) data or base flood depth entered in Item B9.  
 FIS Profile  FIRM  Community Determined  Other (Describe) \_\_\_\_\_  
 B11. Indicate elevation datum used for BFE in Item B9:  NGVD 1929  NAVD 1988  Other (Describe) \_\_\_\_\_  
 B12. Is the building located in a Coastal Barrier Resources System (CBRS) area or Otherwise Protected Area (OPA)?  
 Designation Date \_\_\_\_\_  CBRS  OPA  Yes  No

**SECTION C - BUILDING ELEVATION INFORMATION (SURVEY REQUIRED)**

C1. Building elevations are based on:  Construction Drawings\*  Building Under Construction\*  Finished Construction  
 \*A new Elevation Certificate will be required when construction of the building is complete.  
 C2. Elevations - Zones A1-A30, AE, AH, A (with BFE), VE, V1-V30, V (with BFE), AR, AR/A, AR/AE, AR/A1-A30, AR/AH, AR/AO. Complete Items C2 a-h below according to the building diagram specified in Item A7. Use the same datum as the BFE.  
 Benchmark Utilized Coastal Construction Control B-09 Vertical Datum NGVD 1929  
 Conversion/Comments See attached  
 Check the measurement used  
 a) Top of bottom floor (including basement, crawspace, or enclosure floor) 11.0  feet  meters (Puerto Rico only)  
 b) Top of the next higher floor 11.9  feet  meters (Puerto Rico only)  
 c) Bottom of the lowest horizontal structural member (V Zones only) 19.5  feet  meters (Puerto Rico only)  
 d) Attached garage (top of slab) N/A  feet  meters (Puerto Rico only)  
 e) Lowest elevation of machinery or equipment servicing the building (Describe type of equipment and location in Comments) 11.0  feet  meters (Puerto Rico only)  
 f) Lowest adjacent (finished) grade next to building (LAG) 10.7  feet  meters (Puerto Rico only)  
 g) Highest adjacent (finished) grade next to building (HAG) 11.9  feet  meters (Puerto Rico only)  
 h) Lowest adjacent grade at lowest elevation of deck or stairs, including structural support 11.4  feet  meters (Puerto Rico only)

**SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION**

This certification is to be signed and sealed by a land surveyor, engineer, or architect authorized by law to certify elevation information. I certify that the information on this Certificate represents my best efforts to interpret the data available. I understand that any false statement may be punishable by fine or imprisonment under 18 U.S. Code, Section 1001.

Check here if comments are provided on back of form. Were latitude and longitude in Section A provided by a licensed land surveyor?  Yes  No

Certifier's Name Martin J. Britt License Number 5538  
 Title President Company Name MSB Surveying, Inc.  
 Address 960 Lena Lane City Sarasota State FL ZIP Code 34240  
 Signature Martin J. Britt Date 3-1-2010 Telephone (941) 341-9935

Martin J. Britt  
LS 5538  
3/2/10

**IMPORTANT: In these spaces, copy the corresponding information from Section A.**

Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No. 240 N. Casey Key Rd.  
City Nokomis State Florida ZIP Code 34275

For Insurance Company Use:  
Policy Number \_\_\_\_\_  
Company NAIC Number \_\_\_\_\_

**SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION (CONTINUED)**

Copy both sides of this Elevation Certificate for (1) community official, (2) insurance agent/company, and (3) building owner.

Comments 1) Elevations shown hereon are based on Coastal Construction Control monument B-09 published elevation 10.28 ft NGVD 1929. 2) Second floor is first floor living area and is 23.0 ft NGVD 1929. 3) Lowest elevation of machinery 11.0 ft NGVD 1929  
Signature [Signature] Date 3/2/10  Check here if attachments

**SECTION E - BUILDING ELEVATION INFORMATION (SURVEY NOT REQUIRED) FOR ZONE AO AND ZONE A (WITHOUT BFE)**

For Zones AO and A (without BFE), complete Items E1-E5. If the Certificate is intended to support a LOMA or LOMR-F request, complete Sections A, B, and C. For Items E1-E4, use natural grade, if available. Check the measurement used. In Puerto Rico only, enter meters.

- E1 Provide elevation information for the following and check the appropriate boxes to show whether the elevation is above or below the highest adjacent grade (HAG) and the lowest adjacent grade (LAG).
  - a) Top of bottom floor (including basement, crawlspace, or enclosure) is \_\_\_\_\_ feet  meters  above or  below the HAG.
  - b) Top of bottom floor (including basement, crawlspace, or enclosure) is \_\_\_\_\_ feet  meters  above or  below the LAG.
- E2 For Building Diagrams 6-9 with permanent flood openings provided in Section A Items 8 and/or 9 (see pages 8-9 of Instructions), the next higher floor (elevation C2.b in the diagrams) of the building is \_\_\_\_\_ feet  meters  above or  below the HAG
- E3 Attached garage (top of slab) is \_\_\_\_\_ feet  meters  above or  below the HAG.
- E4 Top of platform of machinery and/or equipment servicing the building is \_\_\_\_\_ feet  meters  above or  below the HAG.
- E5 Zone AO only: If no flood depth number is available, is the top of the bottom floor elevated in accordance with the community's floodplain management ordinance?  Yes  No  Unknown. The local official must certify this information in Section G.

**SECTION F - PROPERTY OWNER (OR OWNER'S REPRESENTATIVE) CERTIFICATION**

The property owner or owner's authorized representative who completes Sections A, B, and E for Zone A (without a FEMA-issued or community-issued BFE) or Zone AO must sign here. The statements in Sections A, B, and E are correct to the best of my knowledge.

Property Owner's or Owner's Authorized Representative's Name \_\_\_\_\_  
Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ ZIP Code \_\_\_\_\_  
Signature \_\_\_\_\_ Date \_\_\_\_\_ Telephone \_\_\_\_\_  
Comments \_\_\_\_\_

Check here if attachments

**SECTION G - COMMUNITY INFORMATION (OPTIONAL)**

The local official who is authorized by law or ordinance to administer the community's floodplain management ordinance can complete Sections A, B, C (or E), and G of this Elevation Certificate. Complete the applicable item(s) and sign below. Check the measurement used in Items G8 and G9.

- G1  The information in Section C was taken from other documentation that has been signed and sealed by a licensed surveyor, engineer, or architect who is authorized by law to certify elevation information. (Indicate the source and date of the elevation data in the Comments area below.)
- G2  A community official completed Section E for a building located in Zone A (without a FEMA-issued or community-issued BFE) or Zone AO.
- G3  The following information (Items G4-G9) is provided for community floodplain management purposes.

G4. Permit Number	G5. Date Permit Issued	G6. Date Certificate Of Compliance/Occupancy Issued
-------------------	------------------------	---

- G7 This permit has been issued for  New Construction  Substantial Improvement
- G8 Elevation of as-built lowest floor (including basement) of the building \_\_\_\_\_ feet  meters (PR) Datum \_\_\_\_\_
- G9 BFE or (in Zone AO) depth of flooding at the building site \_\_\_\_\_ feet  meters (PR) Datum \_\_\_\_\_
- G10 Community's design flood elevation \_\_\_\_\_ feet  meters (PR) Datum \_\_\_\_\_

Local Official's Name \_\_\_\_\_ Title \_\_\_\_\_  
Community Name \_\_\_\_\_ Telephone \_\_\_\_\_  
Signature \_\_\_\_\_ Date \_\_\_\_\_  
Comments \_\_\_\_\_

Check here if attachments

# Building Photographs

Continuation Page

Main House

Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No.			For Insurance Company Use.
840 N. Casey Key Rd.			Policy Number
City	State	ZIP Code	Company NAIC Number
Nokomis	Florida	34275	

If submitting more photographs with: date

South side - A/c



North side - Garage

# Building Photographs

See Instructions for Item A6.

Main House


Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No.			For Insurance Company Use:	
840 N. Casey Key Rd.			Policy Number	
City	State	ZIP Code	Company NAIC Number	
Nokomis	Florida	34275		


If using the Elevation Certificate to obtain NFIP flood insurance, affix at least two building photographs below according to the instr Side View reverse.

Front



Rear





Elevation Certificate

OMB No. 1660-0008

Expires March 31, 2012

Section D – Surveyor, Engineer Or Architect Certification (Continued)  
Attachment Sheet

George & Mary Hicks  
840 N. Casey Key Rd.  
Nokomis, FL 34275

Notes:

1. Elevations shown hereon are based on Coastal Construction Control Line Monument B-09, published elevations 10.28', NGVD 1929.
2. Top of the bottom floor is 11.0', NGVD 1929 which is the bottom of an elevator shaft.
3. Next higher floor is 11.9', NGVD 1929, which are the garage areas.
4. Next higher floor, ground level is 12.4', NGVD 1929, which is an exercise room and storage areas.
5. The second floor is living area 23.0', NGVD 1929.
6. The bottom of the lowest horizontal structural member is 19.5', NGVD 1929.
7. The lowest elevation of machinery servicing the building are A/C units, which are 11.0', NGVD 1929.

A handwritten signature in blue ink, appearing to read 'Martin S. Britt', is written over a horizontal line.

Martin S. Britt, PSM  
License # 5538