



1921

# PLANNING AND DEVELOPMENT SERVICES BUSINESS CENTER

1001 Sarasota Center Blvd., Sarasota, FL 34240  
4000 S. Tamiami Trail, Room 122, Venice, FL 34293  
Sarasota (941) 861-6678 Venice (941) 861-3029

## Velocity Zone Construction Certificate

This form is required for New Construction and Substantial Improvements in Special Flood Hazard Areas designated as V and VE, and structures seaward of the Coastal Construction Control Line (CCCL)\*

Name: Brian Wade Permit No: 1612259702  
Street Address: 1331 Oak Street  
City: Nokomis State FL Zip Code 34275

### SECTION I – Flood Insurance Rate Map (FIRM) Information

Community Number	Panel Number	Suffix	FIRM Index date	Flood Zone/s	Base Flood Elevation	FDEP Elevation <sup>+</sup>
125144	0239	D	May 1, 1984	V16	13'	

### SECTION II – Elevation Information

- |    |   |                  |
|----|---|------------------|
| 1. | Bottom of Lowest Horizontal Structural Member | <u>13.75</u> ft. |
| 2. | Elevation Requirement                         | <u>13.0</u> ft.  |
| 3. | Elevation of Highest Adjacent Grade           | <u>5.7</u> ft.   |
| 4. | Elevation of Lowest Adjacent Grade            | <u>3.7</u> ft.   |
| 5. | Elevation of Bottom of Pilings or Foundation  | <u>TBD</u> ft.   |
| 6. | Elevation of Top of Pile Cap or Grade Beam    | <u>5.0</u> ft.   |

### SECTION III – Certification Statement

(Registered engineer or architect to sign and seal SECTION V)

I certify that based upon development and/or review of structural design specifications, and plans for construction including consideration of the hydrostatic, hydrodynamic, and impact loading involved, that the designs and methods of construction are in accordance with accepted standards of practice for meeting the following provisions:

The bottom of the lowest horizontal structural member supporting the Lowest Floor (excluding the pilings or columns) is elevated to or above Base Flood Elevation or FDEP elevation requirement whichever is higher.

Brian Wade

\* Sarasota County Code Article XVI. Floodprone Areas and Latest Edition of the Florida Building Code

<sup>+</sup> For new construction and substantial improvements that extend wholly or partially seaward of CCCL.

PERMIT # 16 122597 B1

The pile or column foundation, pile cap and/or grade beam, and structure attached thereto is anchored to resist flotation, collapse and lateral movement due to the effects of wind and water loads associated with the design flood elevations acting simultaneously on all of the structural components.

In Zones V and VE fill is not being used for structural support, and entire area below the lowest horizontal member is free of obstructions.

**SECTION IV – Breakaway Construction Certification Statement  
(Registered engineer or architect to sign and seal SECTION V)**

I certify that based upon the development and/or review of structural design, specifications and plans for subject construction that the design and methods of construction of the breakaway walls are in accordance with accepted standards of practice for meeting the following provisions:

Breakaway Wall collapse shall result from a water load less than that which would occur during the Base Flood; and

The area of the Breakaway Wall enclosure below the bottom of the lowest horizontal structural member shall be limited to less than 300 square feet per structure (Zone VE only) and be fully constructed of Flood-Resistant Materials.

Access to such enclosure shall be the minimum necessary to allow for parking of vehicles (garage door) or limited storage of items used in connection with the premises (standard exterior door) or access to the habitable space above (stairway or elevator). The interior portion of such enclosed area shall not be partitioned into separate rooms, or be temperature controlled.

“Breakaway Wall” means a partition independent of supporting structural members that will withstand design wind forces, but will fail under hydrostatic, wave and run-up forces associated with the design storm surge. Under such conditions, the wall will fail in a manner such that it dissolves or breaks up into components that will not act as potentially damaging missiles.

**SECTION V- Certification**

Certifier's Name: JODY YOUNG JR. Title: PE  
License Number: 70781 Company Name: McCall & Young Engineering, LLC  
Street Address: 6849 Energy Court  
City: Sarasota State: FL Zip Code: 34240  
Telephone Number: 941-907-9126 Fax: 941-296-8227

Signature: 

