

RECORD.

- 1. ADDITIONAL REINFORCEMENT SHALL BE AS SPECIFIED BY THE ENGINEER OF
- 2. MINIMUM COMPRESSIVE STRENGTH OF CONCRETE SHALL BE 3000 PSI.
- 3. BEDDING, BACKFILL AND COMPACTION SHALL BE AS SPECIFIED.
- 4. ALL FORM BOARDS SHALL BE REMOVED PRIOR TO BACKFILL.
- 5. NO ALLOWANCE SHALL BE MADE FOR FRICTION BETWEEN THE PIPE WALL AND THE THRUST COLLAR.
- CHART FIGURES CALCULATED FOR 1000 PSF SOIL BEARING, 150 PSI LINE PRESSURE AND A 1.5 FACTOR OF SAFETY.

N.T.S.



ISSUED NOV. 2023

REVERSE THRUST BLOCK

GENERAL DWG NO. 10