



**NOTES:**

1. TRENCH WIDTH SHALL BE APPROX. EQUAL TO THE PIPE DIA. + 2 FEET OR AS PER AWWA AND THE MANUFACTURER'S RECOMMENDATIONS.
2. PROVIDE SHEETING AND SHORING AS NECESSARY IN ACCORDANCE WITH OSHA STANDARDS.
3. BACKFILL MATERIALS SHALL BE APPROVED BY THE ENGINEER WHERE THE PIPE IS UNDERCUT.
4. WATER, SEWER, AND REUSE MAINS TO BE INSTALLED WITH A MINIMUM 36 INCHES OF COVER.
5. FOR COUNTY R/W, REFER TO UNIFIED DEVELOPMENT CODE FOR ROADWAY REPLACEMENT, PAVEMENT OVERLAY AND DENSITY REQUIREMENTS.
6. FOR STATE R/W, REFER TO F.D.O.T. REGULATIONS FOR ROADWAY REPLACEMENT, PAVEMENT OVERLAY AND DENSITY REQUIREMENTS.

N.T.S.

GENERAL\_DWG\_NO-4.DWG 03/2020



ISSUED NOV. 2023

Revision By Appd. YY.MM.DD

TRENCH DETAIL

GENERAL DWG NO. 4