



NOTES:

1. ALL SERVICES SHALL REQUIRE AN INSULATED #10 GAUGE COPPER CLAD STEEL CORE LOCATING WIRE (COPPERHEAD OR APPROVED EQUAL).
2. METER IDLER FOR SINGLE FAMILY RESIDENCES ONLY.
3. CODE APPROVED METER BOX
 BOX: 20"x13"x12"
 LID: 18"x11"x1-3/4" W/2" O/S CELLULAR READ ANTENNA ENDPOINT
 TIER 8 - STANDARD
 TIER 15 - TRAFFICE BEARING

N.T.S.

RECLAIM.DWG_NO-2.DWG 12/2020