

## NOTES:

- MANHOLE SHALL CONFORM TO A.S.T.M. C-478 LATEST REVISION TYPE II CONCRETE, 4000 P.S.I. 28 DAY COMPRESSIVE STRENGTH
- 2. INTERCEPTOR MANHOLES, DROP MANHOLES, AND MANHOLES WITH INTERCEPTING FORCE MAINS SHALL BE LINED IN ACCORDANCE WITH SARASOTA COUNTY UTILITY STANDARDS MANUAL.
- 3. LIFTING HOLES SHALL BE NON-PENETRATING, GROUTED AND COATED.

N.T.S.



ISSUED NOV. 2023

By Appd. YY.MM.DD