



NOTES:

1. AT DISCRETION OF THE COUNTY, COUNTY MAY PERMIT HOMEOWNERS TO USE 1-1/2 INCH PIPING FOR THE SERVICE LINE, WITH HOMEOWNERS ASSUMING ADDITIONAL COSTS THAT MAY BE INCURRED IN PLACING THE LINE INTO SERVICE.
2. 24-INCH MINIMUM COVER ON ALL PIPE AND CONDUIT.

4-FTx6-FT PIT REQUIRES 1.2 CY CAST IN PLACE CONCRETE.

COUNTY MAINTAINED PRIVATELY MAINTAINED

N.T.S.

SEWER_DWG_NO-24.DWG 03/2020



ISSUED	NOV. 2023
By	Appd. YY.MM.DD
Revision	

LOW PRESSURE SEWER SERVICE LAYOUT

SEWER DWG NO. 24