



- NOTE:
1. ALL WOOD SHALL BE PRESERVE PLUS ACQ, CYPRESS, CEDAR, OR EQUAL
 2. 6INCHx6INCH POSTS SHALL BE USED THROUGHOUT.
 3. GATES SHALL BE REINFORCED WITH 1-1/2 INCHØ HOT DIP GALVANIZED STEEL.
 4. HARDWARE SHALL BE A MINIMUM 5/8INCH HOT DIP GALVANIZED STEEL.
 5. GATE TO BE SECURED WITH DROP BAR WITH PADLOCK AND HASP. DROP BAR TO FIT 1INCH SCH. 40 GSP IN 12 INCHØ x 18 INCH DEEP CONC. FOOTING. GATE TO BE SECURED BOTH OPEN AND CLOSED BY TWO GATE STOPS SET IN CONCRETE.
 6. FENCE SHALL BE DESIGNED TO WITHSTAND 130 MPH WIND LOAD.
 7. LATCH HARDWARE SHALL BE AMERISTAR MAXIMA STYLE OR EQUAL.

N.T.S.

SEWER_DWG_NO-27.DWG 03/2020



ISSUED NOV. 2023
 By _____ Appd. _____
 Revision _____

SHADOW BOX WOOD FENCE DETAIL

SEWER DWG NO. 27