



GENERAL NOTES:

1. EACH SERVICE OR DOUBLE WYE SERVICE SHALL HAVE A CLEAN-OUT BROUGHT INTO THE PROPERTY OR CLEAN-OUTS SHALL BE INSTALLED ACCORDING TO THE APPLICABLE SEWER FRANCHISE SPECIFICATIONS.
2. LOCATION OF CLEAN-OUT TO BE ETCHED PERPENDICULAR TO CURB OR EDGE OF ASPHALT WITH BRASS DISC WITH NUMBER OF FEET. REFER TO THE GENERAL SECTION, 2.15.1 FOR SPECIFICATIONS ON DISC IN THE WATER, WASTEWATER, AND RECLAIMED WATER SYSTEMS DESIGN GUIDELIES, MATERIAL STANDARDS, AND INSTALLATION STANDARDS.
3. SERVICE CLEAN-OUT TO EXTEND 2- FEET MIN. ABOVE FINISHED GRADE AT PRELIMINARY UTILITY INSPECTION. SET TO FINAL GRADE AT TIME OF PLUMBER'S TIE-IN, REQUIRED FOR C.O.
4. ALL PIPE SHALL BE 6 INCH DIAMETER.

N.T.S.