



CONTROL PANEL AND STRUCTURE

PLAN VIEW

**NOTES:**

1. DISCONNECT AND CONDUIT FROM DISCONNECT TO CONTROL PANEL TO MEET LOCAL ELECTRICAL CODE.
2. ELECTRICIAN SHALL PROVIDE SUFFICIENT CABLE LENGTH IN SUMP PIT AND CUT EXCESS FLOAT CONTROL CABLES AND POWER CORD.
3. HOMEOWNER TO CONNECT FROM PANEL IN HOUSE TO 30 AMP DISCONNECT.
4. CONTROL PANEL, PROVIDED BY THE COUNTY, SHALL INCLUDE EMERGENCY GENERATOR PLUG WITH TRANSFER SWITCH AND ALARM (VISUAL AND AUDIBLE).
5. ALL EXPOSED EDGES OF CONCRETE SHALL BE CHAMFERED 1 INCH IN UNPAVED AREAS.

N.T.S.

SEWER\_DWG\_NO.25.DWG 03/2020



ISSUED	FEB. 2026
Revision	By Appd. YY.MM.DD

CONCEPTUAL LOW PRESSURE ELECTRICAL LAYOUT

SEWER DWG NO. 25