



**NOTES:**

1. USE OF INSIDE DROP SHALL BE RESTRICTED TO EXISTING MANHOLES ON AN INDIVIDUAL BASIS ONLY, PRE APPROVED BY UTILITY.
2. FOR SPECIFICATIONS AND DIMENSIONS NOT SHOWN, SEE STANDARD DETAIL FOR WASTEWATER GRAVITY COLLECTION SYSTEM.
3. ALL PIPE AND FITTINGS SHALL BE P.V.C. ASTM 3034 SDR 26.
4. ALL BRACKETS, NUTS, BOLTS AND OTHER HARDWARE SHALL BE TYPE 316 STAINLESS STEEL.
5. MANHOLES SHALL BE COATED IN ACCORDANCE WITH SARASOTA COUNTY UTILITY STANDARDS MANUAL.
6. ALL MATERIALS SHALL BE IN ACCORDANCE WITH THE LATEST SARASOTA COUNTY UTILITY STANDARDS MANUAL.
7. TO BE USED ONLY WITH UTILITY DEPARTMENT APPROVAL.

SEWER.DWG\_NO-7.DWG\_03/2020