



GENERAL NOTES:

1. A PERMANENT DIESEL PUMP SHALL BE INSTALLED WITH TRIPLEX LIFT STATIONS. ALL REQUIRED PIPING TO SERVE THIS DIESEL PUMP SHALL BE INSTALLED AT THE TIME OF LIFT STATION CONSTRUCTION.
2. PERMANENT DIESEL PUMPS HAVE DIFFERING PIPE CONFIGURATIONS FOR THE SUCTION AND DISCHARGE PIPE. IN THE DRAWING ABOVE, THE SUCTION PIPE IS ON THE LEFT AND DISCHARGE PIPE ON THE RIGHT.

KEY NOTES:

1. INDIVIDUAL 3/4 INCH DRAIN LINES SHALL CONNECT TO A COMMON 2 INCH DRAIN LINE ONCE PIPES GO BELOW GRADE. DRAIN LINES SHALL BE SCHEDULE 80 PVC.
2. PIPE SUPPORTS SHALL BE PLACED A MINIMUM 6 INCHES FROM THE EDGE OF CONCRETE PAD TO EDGE OF STAND PIPE EDGE.
3. PIPE SUPPORTS SHALL BE 2 INCH DIAMETER ADJUSTABLE 316 S.S. STANCHION SADDLE SUPPORT AND "U" WITH MINIMUM (2) 316 S.S. NUTS ON EACH PIPE SUPPORT AND WITH 0.25 INCH NEOPRENE PADDING BETWEEN EACH SADDLE AND PIPE. PIPE SUPPORTS SHALL BE SECURED TO CONCRETE PAD.

N.T.S.

TRIPLEX_DWG_NO-9.DWG