



MATERIALS

- (A) VALVEBOX WITH COVER SHALL BE BLANK OR SPECIFY "VALVE"
- (B) TUBING AS APPROVED FOR POTABLE SUPPLY USE (Florida Building Code)
- (C) FULL PORT BALL VALVE 1/4 TURN
- (D) RESIDENTIAL DUAL CHECK VALVE (ASSE 1024 APPROVED)

NOTES:

1. REFURBISH OR REPLACE DUC BACKFLOW PREVENTER AT THE DIRECTION OF THE UTILITY
2. MUST CONFORM WITH FLORIDA BUILDING CODE 607.3 THERMAL EXPANSION CONTROL REQUIREMENTS.

N.T.S.