



- NOTES:**
- #10 (AWG) TRACER WIRE (COPPERHEAD OR APPROVED EQUAL) SHALL BE INSTALLED WITH EACH SERVICE.
 - THE METER BOX AND METER STOP SHALL BE INSTALLED SO THE METER REGISTER IS CENTERED ON THE ACCESS HATCH AND PARALLEL TO THE METER BOX.
 - CODE APPROVED METER BOX
BOX: 20"x13"x12"
LID: 18"x11"x1-3/4" W/2" O/S
CELLULAR READ ANTENNA ENDPOINT
TIER 8 - STANDARD
TIER 15 - TRAFFICE BEARING

EXISTING 1 INCH AND 1-1/2 INCH METERS GRANDFATHERED IN SYSTEM AND 2 INCH IN GROUND METERS (FORD ANGLE VALVE METER STOP PART FBFA 43777 W OR APPROVED EQUIV - METER BOX 30 INCH x17 INCH x12 INCH

N.T.S.

WATER_DWG_NO-4.DWG 12/2020