



PLAN

NOTES:

1. THIS DETAIL FOR USE ONLY WHEN THE WATER MAIN IS LOCATED TOO CLOSE TO THE RIGHT-OF-WAY LINE TO USE THE FIRE HYDRANT ASSEMBLY DETAIL.
2. SEE STANDARD GATE VALVE, BOX, LID AND TAG.
3. ALL JOINTS RESTRAINED.
4. FIRE HYDRANTS MAY BE CONSTRUCTED WITH GRADELOK OFFSET FITTING.
5. PRIMER COAT WITH 2 COATS OF EPOXY FOR ALL ABOVE GROUND APPURTENANCES ABOVE 3 INCHES; FIRE HYDRANTS, METER ASSEMBLIES, VALVES, FORCE MAIN ABOVE GROUND ASSEMBLIES, RECLAIM ASSEMBLIES AND BRIDGE PIPE CROSSINGS.

N.T.S.

WATER_DWG_NO-5.DWG 03/2020